

STATE OF FLORIDA  
DEPARTMENT OF HEALTH  
COUNTY HEALTH DEPARTMENT  
PUBLIC SCHOOL  
INSPECTION REPORT



1 of 2

Facility Information

RESULT: Satisfactory

Permit Number: 13-51-08201  
Name of Facility: Coral Reef Sr.  
Address: 10101 SW 152nd Street  
City, Zip: Miami 33157

Correct By: Next Inspection  
Re-Inspection Date: None

Type: Public Schools  
Owner: M-DCSB Food and Nutrition  
Person In Charge: M-DCSB Food and Nutrition  
Phone: (786) 275-0400  
PIC Email:

Inspection Information

Purpose: Routine  
Inspection Date: 11/30/2022

Begin Time: 11:25 AM  
End Time: 12:30 PM

Additional Information

FEMALES ..... 1813  
MALES ..... 1415  
CENSUS ..... 3228

*This form serves as a "Notice of Non-Compliance" pursuant to section 120.695, Florida Statutes. Items marked below violate one or more of the requirements of Rule 6A-2.0010, of the Florida Administrative Code, Chapter 5, section 5 of the State Requirements for Educational Facilities 2014 (SREF); and sections 453 and 468 of the Florida Building Code 6th Edition (2017). Violations must be corrected within the time period indicated above. Continued operation of this facility without making these corrections is a violation. Failure to correct violations in the time frame specified may result in enforcement action being initiated by the Department of Health.*

Violation Markings

SCHOOL SANITATION	IN	11. Group Toilet Rooms	IN	21. Pest Control
IN 1. School Site	OUT	12. Toilet Facilities		SAFETY
IN 2. Playground, Equip & Athletic Fields*	IN	13. Handwashing Facilities	IN	22. First Aid Kit
IN 3. Athletic & Playground Equipment	IN	14. Soap Dispensers		DIAPER CHANGING STATION
BUILDING CONST/MAINT.	IN	15. Shower Facilities	NA	23. Sanitizers
IN 4. Construction	IN	16. Showers Water Temperatures	NA	24. Changing Station & Mats
OUT 5. Maintenance & Repair		WATER SUPPLY	NA	25. Hand Sink
OUT 6. Lighting Standards	IN	17. Approved Source	NA	26. Garbage Can
IN 7. Heating, Ventilation, A/C Standards	IN	18. Drinking Fountains		ANIMAL HEALTH & SAFETY
IN 8. Natural Ventilation		LIQUID WASTE & WASTE WATER	NA	27. Animal Maintenance/Aggressive
IN 9. Mechanical Ventilation	IN	19. Sewage Disposal		DORM/RESIDENTIAL FACILITIES
SANITARY FACILITIES	IN	20. Solid Waste	NA	28. Maintenance/Complaint
IN 10. Provided/Accessible/Separation		PEST CONTROL	NA	29. Other

Marking Key: IN = the act or item was observed to meet standards; OUT = the act or item was observed not to meet standards; NO = the act or item was not observed to be occurring at the time of inspection; NA = the act or item is not performed by the facility or not part of the operation

Violation Key: \* = 2. Playground, Equipment & Athletic Fields

General Comments

Satisfactory.

Email Address(es): ameija@dadeschools.net;  
214020@dadeschools.net

Inspector Signature:

Client Signature:

STATE OF FLORIDA  
DEPARTMENT OF HEALTH  
COUNTY HEALTH DEPARTMENT  
PUBLIC SCHOOL  
INSPECTION REPORT



2 of 2

**Violations Comments**

<p>Violation #5. Maintenance &amp; Repair At the time of this inspection, multiples ceiling tiles with water marks were observed at rooms:140,064,61,66,218,176(dance room), and in front of classroom 176. Replace ceiling tiles. CODE REFERENCE: 5. Maintenance and Repair. 5(1)(e)8.h SREF. Light fixtures and window surfaces, both inside and outside, shall be kept clean, serviceable, and in good repair at all times. 5(1)(e)8.i. Custodial areas shall be kept clean, safe, and orderly at all times. Custodial equipment shall be in good repair at all times. 5(1)(e)8.j SREF. Building components &amp; finishes shall be kept clean &amp; in good repair.</p>
<p>Violation #6. Lighting Standards At the time of this inspection, lightbulbs out were observed at rooms: 142,56,61, and 213. Replace lightbulbs. CODE REFERENCE: 6. Lighting Standards. 468.3.2. FBC. Sources of natural light in instructional spaces shall be glazed with glare reducing materials or shall be shielded to prevent glare that can interfere with seeing task.</p>
<p>Violation #12. Toilet Facilities At the time of this inspection, and urinal was observed out services at restroom 200B. Repair or replace urinal. CODE REFERENCE: 12. Toilet Facilities. 5(16)(b)2.c SREF. Deodorizers shall not be used in toilet rooms. 5(10)(f) SREF. Toilet and bath accessories, including grab bars; toilet paper dispensers; paper towel dispensers or hot-air drying devices; napkin disposal units; shelving, and mirrors, where provided, shall be maintained in a safe and secure condition at all times. The use of common or public towels shall not be permitted. 5(13)(f)4 SREF. Toilet facilities shall have a nonslip, impervious floor, impervious base, and minimum four foot- high impervious wainscot. 5(13)(p)2 SREF. Each staff toilet room shall be provided with at least one water closet and one lavatory and shall be provided with hot and cold water at the lavatory. 5(14)(b)10.a SREF. Walls in toilet rooms shall be finished with impervious materials to a minimum height of four feet. Floor and base in individual or group toilet rooms shall be impervious. 468.3.5.4 FBC. The entry to each group toilet room shall be provided with a door, partition, or other shielding device to block from view the occupants in the toilet room. If a door is provided, it shall have a closer. 5(16)(b)1 SREF. Toilet facilities shall be maintained in a satisfactory state of repair at all times. 5(16)(b)2.a. SREF. Water closets, urinals, lavatories, faucets, flush valves, dispensers, partitions, lower half of walls, and floors shall be maintained in a clean &amp; sanitary condition at all times.</p>

Inspection Conducted By: Pedro Hernandez Bastidas (60752)  
Inspector Contact Number: Work: (305) 623-3500 ex.  
Print Client Name:  
Date: 11/30/2022

Inspector Signature:

Handwritten signature of the inspector.

Client Signature:

Handwritten signature of the client.